

BALTIMORE COUNTY

within [200] 500 feet, measured along a street, alley, or easement, of the public water supply or sewer system and a connection conforming with the standards set forth in the Code may be made thereto. THESE PREMISES SHALL BE CONNECTED TO THE PUBLIC SYSTEMS REGARDLESS OF THE OPERATING CONDITION OF THEIR PRIVATE INSTALLATIONS.

2.24 Toilet Facilities for Workmen

Suitable toilet facilities shall be provided and maintained in a sanitary condition for the use of workmen during construction. (See Table [7.24.2] 2.24.1)

2.1.3 Standards Applicable to Plumbing Materials

A material shall be considered approved if it meets one or more of the standards cited in Table 3.1.3, Standards for Plumbing Materials, and in the case of plastic pipe; also the listed standard of the National Sanitation Foundation. Materials not listed in Table 3.1.3 shall be used only as provided for in Section 3.3.2 or as permitted elsewhere in this Code.

NOTE: Abbreviations in Table 3.1.3 refer to the following organizations:

ANSI	American National Standards Institute 1430 Broadway New York, New York 10018
ASSE	Am Society of Sanitary Engineering 228 Standard Building Cleveland, Ohio 14113
ASTM	Am Society for Testing & Materials 1916 Race Street Philadelphia, Penna. 19103
AWWA	American Water Works Association 521 Fifth Avenue New York, New York 10017
CS	Commercial Standards Commodity Standards Division Office of Industry and Commerce U.S. Department of Commerce Washington, D.C. 20230
FS	Federal Supply Service Standards Division General Services Administration Washington, D.C. 20405
NSF	National Sanitation Foundation